


PM4-WT Rear

← Safe area




Hazardous area →



Shield

Sense repeater optional

External power supply 24VDC @25mA min.



Excitation +

Excitation -

Sense +

Sense -

Signal +

Signal -



Application Note No: AN27



AMALGAMATED INSTRUMENT CO P/L  
5/28 LEIGHTON PL, HORNSBY NSW 2077  
AUSTRALIA PH (02) 9476 2244  
FAX (02) 9476 2902

TITLE: PM4-WT connection to Pepperl+Fuchs barriers & repeaters

DRAWN: AAF DRAWING No. PM4WTP+FCON2 REV. A

APPROVED: DATE: 15/09/98 SHEET: 1 of 1